

# Wastewater Discharge Limitations

Sanitary Discharge and Pretreatment Program Administrative Rules ENB – 4.03

Local Limits		Prohibited Pollutants	
Pollutant	Limit (mg/L)	Pollutant	Limit (mg/L) <sup>1</sup>
<b>Metals</b>		<b>Volatiles</b>	
Arsenic (total)	0.20	Bromodichloromethane	0.0025
Cadmium (total)	0.70	Bromoform	0.0025
Chromium (total)	3.53	Bromomethane	0.005
Copper (total)	2.80	1,1,1,2-Tetrachloroethane	0.0025
Lead (total)	0.70	1,1,2-Trichloroethane	0.005
Mercury (total)	0.010	1,1-Dichloroethene	0.005
Molybdenum (total)	1.40	Chloroethane	0.050
Nickel (total)	2.80	Chloromethane	0.005
Selenium (total)	0.60	Dibromochloromethane	0.0025
Silver (total)	0.40	Vinyl chloride	0.0025
Zinc (total)	3.70	<b>Base/Neutral Extractables</b>	
<b>Non-metals</b>		1,2,4-Trichlorobenzene	0.005
Cyanide (total)	1.20	1,2-Dichlorobenzene	0.005
Oil and grease: non-polar	100	1,2-Diphenylhydrazine	0.0025
pH	5.0 - 11.5 s.u.	1,3-Dichlorobenzene	0.0025
<b>Organics</b>		1,4-Dichlorobenzene	0.005
1,2-Dichloroethane	0.50	2,6-Dinitrotoluene	0.010
2,4-Dinitrotoluene	0.13	4-Bromophenyl-phenyl ether	0.010
Acrylonitrile	1.00	Bis(2-chloroethoxy) methane	0.010
Chlordane	0.03	Bis(2-chloroisopropyl) ether	0.010
Chlorobenzene	0.20	Hexachlorobenzene	0.010
Chloroform	0.20	Hexachlorobutadiene	0.010
Nitrobenzene	2.00	Hexachlorocyclopentadiene	0.010
Pentachlorophenol	0.04	N-Nitrosodi-n-propylamine	0.010
Trichloroethene (TCE)	0.20	<b>Pesticides</b>	
		4,4'-DDD (p,p'-tde)	0.0002
		4,4'-DDE (p,p'-ddx)	0.0002
		4,4'-DDT	0.0002
		a-BHC (alpha)	0.0001
		b-BHC (beta)	0.0002
		c-BHC (delta)	0.0001
		Dieldrin	0.0002
		Endosulfan II (beta)	0.0002
		Endosulfan sulfate	0.0002
		Endosulfan I (alpha)	0.0002
		Endrin	0.0002
		Endrin Aldehyde	0.0005
		g-BHC (gamma) (Lindane)	0.001
		Heptachlor	0.0001
		Heptachlor Epoxide	0.0001
		Toxaphene	0.0009
		<b>Polychlorinated Biphenyls (PCBs)</b>	
		Aroclor 1016	0.00025
		Aroclor 1221	0.0005
		Aroclor 1232	0.00025
		Aroclor 1242	0.00025
		Aroclor 1248	0.00025
		Aroclor 1254	0.00025
		Aroclor 1260	0.00025
<b>Note:</b>			
<sup>1</sup> = Prohibited pollutants are not amendable to treatment or reduction by the sewage process employed or are only partially amendable to treatment. Sample results for prohibited pollutants must be reported to the method detection limit that does not exceed the limit listed.			