FULL INFILTRATION - LEVEL 1



INFILTRATION

PAC CONFIGURATION A



INFILTRATION W/ ROCK GALLERY

PAC CONFIGURATION B



HYBRID

OVERFLOW DIRECTED TO DRAIN ROCK. PAC CONFIGURATION E.

Hybrid facility must be registered as a UIC.

OFFSITE DISPOSAL - LEVEL 2 & 3



LINED

PAC CONFIGURATION D

IF NO LINER, CONFIGURATION C WITH LOWERED OUTLET



UNLINED - STANDARD

PAC CONFIGURATION C

PAC CONFIGURATION C WITH ELEVATED OUTLET



UNLINED - RECESSED

PAC CONFIGURATION C WITH ELEVATED OUTLET

ALL OUTLETS TO APPROVED DISCHARGE POINTS PER SWMM CHAPTER 1

- DRAWING NOT TO SCALE -

PRESUMPTIVE AND PERFORMANCE DESIGN APPROACH

Bureau of Environmental Services

STORMWATER MANAGEMENT
TYPICAL DETAILS FOR
PRIVATE PROPERTY

CONFIGURATION
CROSS SECTIONS

SW-216

12/10/24