

STANDARD VIOLATION CODES

Violation Ref.	Violation / Description	Fire Code Reference
	B = Building Code; P = FMO Policies; M = Mechanical Code; N = NFPA; E = Electrical Code; T = City Code; U = Uniform Fire Code	
	FIRE ALARM SYSTEMS	
A01	STROBES -FIRE ALARM SYS	901.6; 907.1, .2, .3
A03	REPAIR ALARM SYSTEM	901.6
A06	TEST REPORT STATUS	P FIR 6.02; 901.6.3
A07	PULL STATION SIGN (SELF-ADHESIVE SIGNS AT FMO)	P FIR 6.02; 907.4.2.4
A08	PULL STATIONS OPERABLE	901.6
A09.1	REPAIR REQUIRED DETECTORS	901.6
A10.1	REMOVE OR REPAIR NON REQUIRED DETECTORS	901.6; N 72-17.5.3.3.2
A11	MAINTAIN ACCESS TO ALARM EQUIPMENT	509.2
A12	REMOVE DETECTOR DUST COVERS	901.6; N 72-14.2.2.2
A13	REPAIR HEAT DETECTORS	901.6
A14	NAME CENTRAL MONITORING COMPANY	N72-26.3.4
A15	EXTEND ALARM SYSTEM	901.4
A16.1	SMOKE DETECTOR/ALARM, PER PUFC 9002, STAND. 10-2	907.2.10.1
A17	PROVIDE REQUIRED MAINTENANCE/TESTIN OF FIRE SYSTEM	907.8; N 72-10.3.2, .14
A18	SECURITY ALARM SYSTEM	901.6; P FIR 6.08
A19	RESPONSIBLE PARTY	901.7; N72-10.21
A21	FIRST WARNING LETTER FOR COMM REPEAT FALSE ALARMS	T 31.10.070 (A.7); P FIR 6.0
A22	2ND NOTICE. WARNING OF POSSIBLE CITATION.	T 31.10.070 (A.7); P FIR 6.0
A23	REPEAT FALSE ALARM FINAL NOTICE.	T 31.10.070 (A.7); P FIR 6.0
A24	CITATION ISSUED- NON-COMPLIANCE WITH REQUIREMENTS	T 31.10.070 (A.7); P FIR 6.0

STANDARD VIOLATION CODES

Violation Ref.	Violation / Description	Fire Code Reference
	B = Building Code; P = FMO Policies; M = Mechanical Code; N = NFPA; E = Electrical Code; T = City Code; U = Uniform Fire Code	
A25	ALARM SYSTEM TEST	P FIR 6.02 Section IV; 901.6.2
A26	ALARM SYSTEM TEST	P FIR 6.02 Section IV
A27	ALARM SYSTEM TEST	P FIR 6.02 Section IV
A28	ALARM SYSTEM TEST	P FIR 6.02 Section IV; PCC 31.20.100
A29	ALARM SYSTEM TEST	907.8; 909.20.3; N72-10.5.3; P FIR 6.02 Section IV
A30	ALARM SYSTEM SENSITIVITY TEST	907.8.3; 907.8.4
A31	ALARM SYSTEM TEST	907.8.2 909.20.3 N72-TABLE 14.4.3.2; P FIR 6.02
A32	ALARM SYSTEM SENSITIVITY TEST	907.8.3; 907.8.4; P FIR-6.02.IV.J
A33	DAS SHALL BE INSPECTED AND TESTED ANNUALLY.	510.6.1
A34	PROVIDE DAS "AS-BUILT" DESIGN DOCUMENTS.	510.4.2.7
A99	FIRE ALARM SYSTEMS "OTHER" CODE	
	BUILDING IDENTIFICATION	
B01	UNOBSTRUCT ACCESS RDS/FIRE LNS	503.4
B02	EMERGENCY ACCESS TO EXT DRS	504.1
B03	INSURE OPERABILITY OF DAMAGED HYD	507.5.2
B04	ADDRESS IDENTIFICATION	505.1
B05	KEY BOX	506.1
B07	CLEAR ACC TO FIRE DEPT. CONNECT	507.5.4
B08	3 FT. CLEAR AROUND FIRE HYD	507.5.5
B09	ACCESS TO LOCKED AREAS	104.3
B10.1	GUARD POSTS/IMPACT PROTECTION	312; 507.5.6

STANDARD VIOLATION CODES

Violation Ref.	Violation / Description	Fire Code Reference
	B = Building Code; P = FMO Policies; M = Mechanical Code; N = NFPA; E = Electrical Code; T = City Code; U = Uniform Fire Code	
B11	RUBBISH STORAGE, PERMIT	304
B12	GENERATOR TESTING	N110-8
B99	BUILDING ID/SITE ISSUES "OTHER" CODE	
	RESTAURANTS	
C02	CLEAN HOOD AND DUCT	607.3.3
C03	EXTINGUISHING SYS- COOK EQUIP.	904.2.2
C04	TYPE 1 HOOD & VENT SYS REQUIRED	607.2
C05	K-TYPE EXTINGUISHER IN KITCHEN	906.4
C06	CIGARETTE DISPOSAL CONTAINERS	310.7
C07	HOOD & VENT SERVICE	904.11.6.2
C08	LISTED GREASE FILTERS ONLY	609.3.1
C09.1	SIGN FOR 'NO GREASE COOKING'	BDS CODE GUIDE UMC/5/#1
C11	HOOD AND VENT EXTINGUISHING SYSTEM	904.11
C12	CLEARANCE FROM DEEP FAT FRYER	N96-12.1.2.4 & .5
C99	COMMERCIAL KITCHENS/RESTAURANT "OTHER" CODE	
	DRY CLEANING	
D02	MAQ AND TYPE I DISPENSING	2106.2 & .3
D99	DRY CLEANING PLANT "OTHER" CODE	
	ELECTRICAL	
E01	OBJ HANG ON WIRING; NOT SECURE	604.1; 604.6; 604.9.1
E02	EXT CORD THRU WALLS, UNDER DRS	604.4.3; 604.5
E03	GANG PLUGGING POWER TAPS	604.4.2
E04	MODIFIED OR DAMAGED ELEC EQUIP.	604.1
E05	EXTENSION CORD USE	604.5
E06	MULTI-PLUG ADAPTERS	604.4
E07	NON-APP.APPLI IN HEALTH CARE FAC	604.10.5
E08	LABEL DISCON CIRCUIT FOR PURPOSE	604.3.1
E09.1	CLEARANCE FROM ELECTRICAL PANEL	604.3

STANDARD VIOLATION CODES

Violation Ref.	Violation / Description	Fire Code Reference
	B = Building Code; P = FMO Policies; M = Mechanical Code; N = NFPA; E = Electrical Code; T = City Code; U = Uniform Fire Code	
E10.1		604.8
E11	EMERGENCY LIGHTING OPERATIONAL	1008.3.5
E12	COVER PLATES	604.6
E13.1	EXPO WIRES/COVERS MISS FROM BOXES	604.6
E14	DISCONTINUE USE OF PLUG ADAPTERS	604.5.4
E16	PROVIDING WIRING APPROPRIATE FOR LOCATION	604.1
E99	ELECTRICAL "OTHER" CODE	
	FIRE PROTECTION	
F01.1	FIRE WATCH AFTER FLAME PROD DEVICE	3504.2.1
F02	REPAIR SEPARATION WALLS	703.1
F03	PLAN FOR HIGH PILED COMB STORAGE	3201.3.1
F04	ANNUAL TEST FOR FIRE DOOR	705.2.6
F05.1	FIRE DRILL RECORDS	405.5
F06.1	HAZARDOUS MATERIALS VENTING	105.1.1
F99	FIRE PROTECTION SYSTEMS "OTHER" CODE	
	REPAIR GARAGE	
G01	FLOOR CLEAR FROM SPARK OR FLAME	2311.3
G02.1		2311.2.1
G99	REPAIR GARAGE "OTHER" CODE	
	HAZMAT	
H01.1	FLAMM LIQUIDS IN CLASSROOMS	5704.3.4.2
H02.1	SPRINKLERS FOR 'USE OPEN'	5704.3.5.1
H02.2	SPRINKLERS FOR BASEMENT STORAGE	5704.3.5.1
H03	FLAMM LIQUID STORAGE CABS	5704.3.2.1.3
H04	FLAMM /COMB LIQUIDS MAQ'S	5704.3.4.2; TABLE 5003.1.1
H05	MARKING FOR PIPING SYSTEMS	5303.4.3
H06.1	LABEL FLAMM LIQ TANKS OVER 100 GALLONS	5704.2.3.2
H07	PROVIDE MSDS	407.2

STANDARD VIOLATION CODES

Violation Ref.	Violation / Description	Fire Code Reference
	B = Building Code; P = FMO Policies; M = Mechanical Code; N = NFPA; E = Electrical Code; T = City Code; U = Uniform Fire Code	
H09	SEPARATE INCOMPATIBLES	5003.9.8
H10	ORDERLY HAZMAT STORAGE ON SHELVES	5003.9.9
H11.1	HAZMAT AT OR BELOW MAQ	5003.1.1
H12	SPILL CONTROL AND CONTAINMENT	5004.2
H13.1	SAFETY CAN	5003.9.10
H14	HAZARDOUS MATERIALS SIGNS	5003.5
H15	HAZARDOUS MATERIALS SIGNS	5003.5
H99	HAZMAT / FLAM LIQ "OTHER"	
I01	HEADROOM CLEARANCE/OBSTRUCTION IN EGRESS	1003.3.1
I02	DOORS LEFT OPEN, COMPROMISING EXIT/EGRESS	N 101, 7.2.1.8 & STANDARD "Q"
I03	FAILURE TO USE ALARM SYS TO INITIATE FIRE DRILL	N 101, 14.7.2.4
I04	NO PROTECTIVE GUARDS OVER ALARM DEVICES	N 101, 9.6
I05	EXCESSIVE COMBUST. WALL HANGINGS IN EXIT CORRID	P FIR 3.02 E (2)
I06	ABSENCE OF INTERCONNECTED SMOKE ALRMS WHEN REQUIR	907.2.6
I07	NOZZLES WITH SHUTOFFS REQUIRED ON HOSE IN S/P CAB	N 101, 9.7.4.2 & N 14
I08	SMOKE GASKETS ON FIRE DOORS DAMAGED OR MISSING	703.1
I10.1	DECORATIVE LIGHTING	P FIR 3.02, IIC
I11	FILE CABINETS IN EXIT PATHWAY NOT SECURED TO WALL	N 101, 7.1.10.1
I12	EMER. EVACUATION MAPS NOT POSTED OR NEED AMEND	404.2
I13	NO RECORD OF BATTERY BACKUP LIGHTING TESTS	N 101, 7.9.3.1.2
I14	SWINGING FIRE DOORS TO CLOSE & LATCH	703.2.3
I99	OTHER VIOLATIONS FOUND, NOT DESIGNATED IN SVC	
	FIRE PUMP	
J01.1	FIRE PUMP TESTING	901.6.1; N25-8.3.1

STANDARD VIOLATION CODES

Violation Ref.	Violation / Description	Fire Code Reference
	B = Building Code; P = FMO Policies; M = Mechanical Code; N = NFPA; E = Electrical Code; T = City Code; U = Uniform Fire Code	
J03.1	SYSTEM TEST REPORTS ON SITE, 3 YEARS	901.6.1
J04.1	FIRE & LIFE SAFETY EVACUATION PLAN	403.10.3.1.1
J06	ANNUAL MAINT. TO F&LS AND EVAC PLANS (REQ./REC.)	405.5
J08	RECORD OF ANNUAL TRAINING OF EMPLOYEES	405.2
J09	RECORD OF RESIDENT TRAINING AND/OR REQUIRED DRILL	408.1
J99	HI-RISE "OTHER" CODE	
	HOUSEKEEPING	
K01	SMOKING OUTSIDE OF DESIG AREAS	310.1
K02	COMBUSTIBLES UNDER STAIRS	315.3.4
K05.1		6103.2
K06	COMBUSTIBLES @ BLDG. EXT	304.1
K07.1	PORTABLE HEATER	604.1
K08	OPEN FLAME / SPARK - DUST AREA	2203.1
K09	PORTABLE/FUEL FIRED SPACE HEAT	603.4
K10	5 FT.CLEARANCE OF DUMPSTER	304.3.3
K11	ACCUMULATION OF DUST	2203.2
K12.1	CLEARANCE FROM STORAGE TO CEILING, 24"	315.3.1
K13	ORDERLY STORAGE OF COMBUST	315.3
K14	RECYCLING MATERIALS STORAGE	319
K15.1	DUST COLLECTION INTERLOCK	2803.2
K16.1	FLAMMABLE LIQUID STORAGE CABINET	5704.3.2
K17	METAL TRASH CONTAINER	304.3.2
K18	CLEAN AIR FILTERS- SPRAY BOOTH	2404.7.8
K19.1	FIRE RETARDENT TREATMENT	807
K20.1	ASHTRAYS, MATCH RECEPTACLES	310.6
K21	LISTED CAN FOR OILY RAGS	304.3.1
K22	CLEAR COMBUST FROM HEAT APP	305.1
K23	TIP-OVER PROTECT FOR COMP GASES	5303.5
K25	FIRE RETARD FOR COMB WALL HANG	807

STANDARD VIOLATION CODES

Violation Ref.	Violation / Description	Fire Code Reference
	B = Building Code; P = FMO Policies; M = Mechanical Code; N = NFPA; E = Electrical Code; T = City Code; U = Uniform Fire Code	
K27	CLEAN SPRAY BOOTH	2303.4
K28.1	COMBUSTIBLE STORAGE IN BOILER/MECH/ELEC ROOMS	315.3.3
K29	NON-APPR WALL/CEILING MATERIAL	807
K30	RESTORE FIRE RESISTIVE CONSTRUCTION	703.1
K32.1	SELF CLOSING CHUTES / DOORS /TERMINUS	704.2; B713.13.1
K99	HOUSEKEEPING "OTHER" CODE	
	PANIC HARDWARE	
L01.1	PANIC HARDWARE	1010.1.10
L03.1	aisle width	3103.12.5
L04.1	aisle width	TABLE 1029.6.2
L05	EXIT PATH	1003.6
L06.1	EGRESS LIGHTING	1008.1
L07	OCCUPANT LOAD POSTING	1004.9
L08.1	ROW SPACING	1029.1
L11.1	FLAME-RETARDENT TREATMENT	3104.2
L12.1	EXIT PLACEMENT	3103.12.1
L13.1	EXITS	3103.12.2; TABLE 3103.12.2
L14	MAINTAIN PROPER CLEARANCE OF MEANS OF EGRESS	3103.12.8
L15.1	PANIC HARDWARE	1008.1.10
L18.1	EXIT DISTANCE	1029.7
L22	PANIC HARDWARE	1010.1.6
L23	aisle width	1029.6.1
L24	aisle width	1029.6.1; TABLE 1029.6.2
L99		
LO2.1	EGRESS WIDTH	1003.6

MOORAGE AND WATERFRONT

STANDARD VIOLATION CODES

Violation Ref.	Violation / Description	Fire Code Reference
	B = Building Code; P = FMO Policies; M = Mechanical Code; N = NFPA; E = Electrical Code; T = City Code; U = Uniform Fire Code	
M01	MOORAGE IDENTIFICATION PLAN	PCC 28.06.070
M04	FLOATING HOME MOORAGES	PCC 19.16.250(G)
M05	MOORAGE STANDPIPE	PCC 28.05.020, A.2
M06	MOORAGE STANDPIPE TESTED	PCC 28.05.020, A.2(J); N25-6.3
M07		901.6; N25-6.3.2.2; PCC 28.04.
M08		N25-6.5 REFERS TO N13-9.1.1.7
M09		PCC 19.16.135E
M10		PCC 28.07B & 28.07.020
M11.1	MOORAGE ADDRESSING	505.1; PCC 28.06.070
M12	30 AMP MIN SHORE POWER SUPPLY	N70 ARTICLE 555.19
M13	1 FT. CANDLE/SQ.FT. AT EGRESS WALKING SERVICE.	PCC 28.06.060
M14	6 FEET MINIMUM WALKWAY WIDTH.	PCC 28.08.060 (D)
M15	24 INCH WALK ACCESS ON 2 SIDES OF FLOATING HOMES	PCC 28.08.060
M16	FLOATING HOME SPACING - 10-FT WALLS & 8-FT ROOFS.	PCC 28.06.050
M17	PROVIDE PILINGS TO WITHSTAND EXPECTED FORCES/LOAD	PCC 28.06.040
M18	PROVIDE ADEQUATE, STABLE WALKWAY FLOATATION SYS	PCC 28.08.040
M19.1	MOORING CONNECTIONS	PCC28.06.030
M20	PROVIDE VISIBLE STATE ISSUED I.D. PLATE.	PCC 28.06.070; ORS 830.850
M21	MAINTAIN ALL ELEC, PLUMBING & MECH INSTALLATIONS	PCC 28.04.020

STANDARD VIOLATION CODES

Violation Ref.	Violation / Description B = Building Code; P = FMO Policies; M = Mechanical Code; N = NFPA; E = Electrical Code; T = City Code; U = Uniform Fire Code	Fire Code Reference
M22	DO NOT ALLOW ANY OIL PRODUCT TO FLOW INTO RIVER.	PCC19.16.145
M23	SUBMERSIBLE POLYSTYRENE MUST BE ENCAPSULATED.	ORS 830.955
M99	MOORAGE AND WATERFRONT "OTHER CODE"	
MO2.1	MOORAGE MAINTENANCE	PCC 28.04.020
MO3.1	MOORAGE EXTINGUISHERS	906.2
	SIGNAGE	
N01	OCCUPANCY LOAD SIGN	1004.9
N02	LOCATION OF FIRE EXTINGUISHER SIGN	906.5
N03	REMAIN UNLOCKED SIGN ON FRONT DR	1010.1.9.4
N04	SPRINKLER ALARM BELL SIGN	N 13 TABLE A.16.11.2
N05.1	FIRE DOOR - DO NOT BLOCK SIGN	705.2.2
N06	SPRINKLER RM, "ELECTRICAL RM" SIG	509.1
N07	ELECTRICAL CONTROL PANEL RM SIGN	604.3.1
N08.1	FIRE DOOR - KEEP CLOSED SIGN	1023.9
N09	OPEN CLASSROOM DOORS	STANDARD Q
N10		705.2.2
N99	SIGNAGE "OTHER" CODE	
	PERMITS	
P01	WELDING & CUTTING OPERATIONS PERMIT	3501.3; T 31.40.030(h) (10)
P02	LEGALIZE WIRING	604.1
P03	CHANGE OF USE FOR OCCUPANCY PERMIT	102.3
P04.1	ILLEGAL SECOND EXIT	1006.2.1; TABLE 1006.2.1
P05.1	ILLEGAL SPRAY BOOTH	2404.3.1
P06	PROOF OF OCCUPANCY	102.3
P07	REMODEL/REPAIR PERMITS	102.4
P99	PERMITS "OTHER" CODE	

ELEVATOR REQUIREMENTS

STANDARD VIOLATION CODES

Violation Ref.	Violation / Description	Fire Code Reference
	B = Building Code; P = FMO Policies; M = Mechanical Code; N = NFPA; E = Electrical Code; T = City Code; U = Uniform Fire Code	
Q01	ELEVATOR SIGNAGE	606.3
Q01.1	ELEVATOR SIGNAGE	606.3
Q02	NO SMOKING SIGNS IN ELEVATORS	310.3
Q99	ELEVATOR REQUIREMENTS "OTHER" CODE	
	APARTMENTS	
R01	FUELED EQUIPMENT STORAGE	313.1
R02.1	SMOKE ALARM/DETECTOR FOR SLEEPING AREA	PCC 29.30.240
R03	CLEAN DRYER LINT TRAP	304.1
R04.1	DRYER VENTING	105.1.1
R05.1	SMOKE DETECT TEST WRITTEN DOC	P FIR 6.10
R07	COMBUSTIBLE WASTE MATERIAL	304.3.2
R99	APARTMENTS "OTHER" CODE	
	SPRINKLER/STANDPIPE	
S01	HANGING OBJ FROM SPRINKLER PIPES	N 13-9.1.1.8.1
S02	STOR IN FRONT/ARND SPRINK VALVE	509.2
S03	EXTEND FIRE PROTECTION SYSTEMS	901.4
S04	SECURE SPRINK CONTROL VALVE OPEN	N 13-8.16.1.1.2. 1
S05	SECURE POST INDICATOR VALVE OPEN	N 13-8.16.1.1.2. 1
S06	WET STANDPIPE CABINET CONDITION	901.6; N25-1992
S08.1	CENTRAL MONITORING FOR SPRINKLER SYSTEM	903.4 EXC 2
S10	IDENT ALL VALVES ON SPRINK SYS	N 13-7.7.1.5
S11	REPAIR SPRINKLER SYS USING FM APPROVED EQUIPMENT	901.6
S12	SIGN TO IDENTIFY F.D.C.	912.4
S13	SPRINKLER HEAD BOX / CONTENTS	N 13 6.2.9.1
S14	PLUGS / CAPS FOR F.D.C.; SWIVEL OP	901.6
S15	SPRINK IN RUBBISH / LINEN CHUTES	903.2.11.2
S16	MISSING ESCUTCHEONS	901.6

STANDARD VIOLATION CODES

Violation Ref.	Violation / Description	Fire Code Reference
	B = Building Code; P = FMO Policies; M = Mechanical Code; N = NFPA; E = Electrical Code; T = City Code; U = Uniform Fire Code	
S17	CLEANING SPRINKLER HEADS	901.6
S18	REPLACE PAINTED SPRINKLER HEADS USING FM APPROVED	N25-5.2.1.1.1
S19	REHANG FIRE HOSE IN CABINET	N25-6.2.7.1
S20	FIRE PUMP TEST	TABLE 901.6.1;N 25-8.3.3
S22	SPRINKLERS OBSTRUCTED.	N 13-8.5.3
S23	NO RECORD OF ANNUAL PRIVATE HYDRANT TEST	N 25-7.3; Table 7.1
S24	STORAGE CLEARANCE TO CEILING	315.3.1
S25	COOKING EQUIPMENT EXTINGUISHING SYSTEM	904.12
S26	FIXED SYSTEM SERVICE EVERY 6 MONTHS	904.12.5.2
S27	HYDRAULIC DESIGN SIGN	N 13-25.5.1
S29	CENTRAL MONITOR FOR SPRINK SYSTEM	903.4 EX. #2
S30	INSPECTION/TESTING OF SPRINKLERS	901.6.1; N 25-5
S31	INSPECTION/TESTING OF STANDPIPE	901.6.1; N 25-5
S32	INSPECTION/TESTING OF HYDRANT	901.6.1; N 25-5
S33	SPRINKLER SYSTEM REPAIR & MAINTENANCE	901.6
S34	TEST OR REPLACE SPRINKLER HEADS	N 25-5.3.1.1.1; N 25-5.3.1.2
S35	TEST OR REPLACE SPRINKLER HEADS	N 25-5.3.1.1.1.5; N 25-5.3.1.2
S36	TEST OR REPLACE SPRINKLER HEADS	N 25-5.3.1.1.1.3; N 25-5.3.1.2
S37	TEST OR REPLACE SPRINKLER HEADS	N 25-5.3.1.1.1.6; N 25-5.3.1.2
S38	TEST OR REPLACE SPRINKLER HEADS	N 25-5.3.1.1.2; N 25-5.3.1.2
S39	TEST OR REPLACE SPRINKLER HEADS	N 25-5.3.1.1.1.4; N 25-5.3.1.2

STANDARD VIOLATION CODES

Violation Ref.	Violation / Description	Fire Code Reference
	B = Building Code; P = FMO Policies; M = Mechanical Code; N = NFPA; E = Electrical Code; T = City Code; U = Uniform Fire Code	
S40	REPLACE SPRINKLER HEADS	N 25-5.3.1.1.1.2
S41	HIGH PILED STORAGE	3201.1
S42	FIRE DEPARTMENT CONNECTION CLEARANCE	912.4.2
S99	SPRINKLER/STANDPIPE "OTHER" CODE	
	FIRE EXTINGUISHERS	
T01	BLOCKED FIRE EXTINGUISHERS	906.6
T02	FIRE EXTINGUISHER MOUNTING	906.9; N 10-6.1.3.8.1
T03	FIRE EXTINGUISHER LOCATION SIGNS	906.6
T05	PROVIDE FIRE EXTINGUISHER ANNUAL SERVICE	N 10-7.3
T06	EXTINGUISHER @ STORAGE ENTRANCE	2108.4
T08.1	EXTINGUISHER LOCATION	TABLE 906.1
T09	2A-10BC EXTING IN LAUNDRY ROOM	906.3
T10.1	FIRE EXTINGUISHER	906.3
T11	EXTINGUISHERS FULLY CHARGED AND OPERATIONAL	901.6
T12	EXTINGUISHERS IN DESIGNATED PLACE	901.4.1
T13	EXTINGUISHERS FOR HOT ROOFING	303.5
T14	EXTINGUISHERS FOR BUILDING PAINT REMOVAL	308.1.3
T99	FIRE EXTINGUISHER "OTHER" CODE	
	FUELING	
U02	EMERGENCY SHUT-OFF SWITCH	2303.2
U03	SIGN -" EMERGENCY FUEL SHUTOFF"	2303.2
U04.1	EXTINGUISHER BY FUEL PUMPS	2305.5
U05	FUEL DISPENSING SIGNS	2305.6
U99	FUELING "OTHER" CODE	
	SPRAYING	
V01.1	SPRAY BOOTH CLEANING/CLEARANCE	2404.3.3.5
V02	COVER SPRINKLER HEADS IN SPRAY AREA	2404.5.2
V03	WASTE CAN FOR RAGS	2403.4.3
V04	EXTINGUISHER FOR SPRAY/DIP AREA	2404.4.1

STANDARD VIOLATION CODES

Violation Ref.	Violation / Description B = Building Code; P = FMO Policies; M = Mechanical Code; N = NFPA; E = Electrical Code; T = City Code; U = Uniform Fire Code	Fire Code Reference
V05	INTERLOCKS FOR SPRAYING	2404.6.1.2.1
V06.1	FLAME/SPARKS IN SPRAY AREA	2403.2.2
V07.1		2403.4; 2403.4.2
V08	GROUNDING AND BONDING	2403.2.5; 2403.3.4; 2406.6.4
V09	ELECTRICAL IN SPRAY AREA	2404.6.2.4
V99		
	STORAGE	
W01	STORAGE PLANS	3201.3
W02	MAINTAIN PILE DIMENSION AND HEIGHT LIMITATIONS.	3205.5; 3207.3; Table 3206.2
W03.1	PLASTIC STORAGE	3203.9
W04	MAINTAIN STRUCTURAL INTEGRITY OF RACK STRUCTURES.	3205.1
W05		3205.3
W06		2305.4
W06.1	KEEP AISLES CLEAR	3205.4
W07.1	KEEP AISLES CLEAR	3205.4
W08.1	KEEP AISLES CLEAR	3205.4; 3206.9
W09.1	SPRINKLERS FOR SHELF STORAGE	3207.2.1
W10		3208.2.1
W11	MAINTAIN REQUIRED FLUE SPACES.	3208.3
W12	CAROUSEL STORAGE	3209.3
W13	SEISMIC BRACING OF RACKS	3205.1; 202
W99	HIGH-PILED COMBUSTIBLE STORAGE "OTHER" CODE	
	EXITS	
X01	BLOCKED EXIT DOOR	1031
X02	BLOCKED EXIT PATHWAY	1031
X03	COMB STORAGE IN EXIT	315.3.2
X04	CONCEALMENT/OBSTR-EXIT SIGN	1031.4

STANDARD VIOLATION CODES

Violation Ref.	Violation / Description	Fire Code Reference
	B = Building Code; P = FMO Policies; M = Mechanical Code; N = NFPA; E = Electrical Code; T = City Code; U = Uniform Fire Code	
X05	FLAMM./COMB LIQ @ EXIT OR STAIRS	315.3.2
X06	OBSTRUCTED FIRE ASSEMBLY EXIT	705.2
X07	ILLEGAL SECURITY HARDWARE	1030.5
X08	CLEAR EXIT PATH TO SAFE DISPERSAL	1028.5
X09	EMERGENCY EXIT LIGHTING OPER	1013.3
X11	EXIT SIGN REQUIRED	1013.1
X12.1	UNAPP REL MECH.-GATES & BARRIERS	1010.2
X14.1	EXIT DOOR SWING DIRECTION	1010.1.2
X16	LOCKS, LATCH AND CHAINS-EXIT DRS	1010.1.9.4
X17	SELF-CLOSING & LATCHING FIRE DRS	705.2.3
X18	ILLUMINATION OF EXIT SIGNS	1013.1
X20	CLEARLY MARK EXITS	1013.1
X21	EXIT DOORS OPERABLE	1010.1.9
X22	MAINTAIN FIRE DOORS	705.1
X23.1	FIRE DOOR INSPECTION/TESTING	705.2.6
X24.1	Periodic Testing of Emergency Lighting Equipment	1031.10.2
X26	EXIT SIGN	1031.5
X27	EXIT MARKING	1030.5
X28	FIRE ESCAPE TESTING	P FIR 2.08
X29	FIRE ESCAPE TESTING	P FIR 2.08
X99	EXITS "OTHER" CODE	
	SECONDARY CONTAINMENT	
Y01	WELLHEAD PROTECTION PROGRAM VIOLATION	WHPP 3.1.4
Y02	WELLHEAD PROTECTION PROGRAM VIOLATION	WHPP 3.1.4
Y03	WELLHEAD PROTECTION PROGRAM VIOLATION	WHPP 3.1.4
Y04	WELLHEAD PROTECTION PROGRAM VIOLATION	WHPP 3.3.1.1
Y05	WELLHEAD PROTECTION PROGRAM VIOLATION	WHPP 3.3.2
Y06	WELLHEAD PROTECTION PROGRAM VIOLATION	WHPP 3.3.2
Y07	WELLHEAD PROTECTION PROGRAM VIOLATION	WHPP 3.4.1.1.1

STANDARD VIOLATION CODES

Violation Ref.	Violation / Description	Fire Code Reference
	B = Building Code; P = FMO Policies; M = Mechanical Code; N = NFPA; E = Electrical Code; T = City Code; U = Uniform Fire Code	
Y08	WELLHEAD PROTECTION PROGRAM VIOLATION	WHPP 3.4.1
Y09	WELLHEAD PROTECTION PROGRAM VIOLATION	WHPP 3.4.1 & 3.4.1.1.2
Y10	WELLHEAD PROTECTION PROGRAM VIOLATION	WHPP 3.4.1.1.2
Y11	WELLHEAD PROTECTION PROGRAM VIOLATION	WHPP 3.4.2
Y12	WELLHEAD PROTECTION PROGRAM VIOLATION	WHPP 3.4.2
Y13.1	WELLHEAD PROTECTION PROGRAM VIOLATION	WHHP 3.4.2
Y14.1	WELLHEAD PROTECTION PROGRAM VIOLATION	WHPP 3.4.2
Y15	WELLHEAD PROTECTION PROGRAM VIOLATION	WHPP 3.5.1.1.1
Y16	WELLHEAD PROTECTION PROGRAM VIOLATION	WHPP 3.5.2
Y17	WELLHEAD PROTECTION PROGRAM VIOLATION	WHPP 3.6.1
Y18	WELLHEAD PROTECTION PROGRAM VIOLATION	WHPP 3.7.1.1
Y19	WELLHEAD PROTECTION PROGRAM VIOLATION	WHPP 3.8.1.3
Y20.1	WELLHEAD PROTECTION PROGRAM VIOLATION	WHPP 3.10
Y21	WELLHEAD PROTECTION PROGRAM VIOLATION	WHPP 3.10
Y22.1	WELLHEAD PROTECTION PROGRAM VIOLATION	WHPP 5.1
Y23	WELLHEAD PROTECTION PROGRAM VIOLATION	WHPP 5.2
Y99	WELLHEAD PROTECTION PROGRAM VIOLATION	
	FIRE CODE CITATIONS	
Z31	FAILURE TO OBTAIN A PERMIT	T 31.10.070 (A 1)
Z32	FAILURE TO ADHERE TO PERMIT CONDITIONS	T 31.10.070 (A 2)
Z33	FAILURE TO ADHERE TO ASSIGNED OCCUPANT LOAD LIMIT	T 31.10.070 (A 3)
Z34	FAILURE TO OBTAIN A PROPANE PERMIT	T 31.40.020
Z35	FAILURE TO USE, MAINT, STORE OR SECURE PROP TANK	T 31.10.070 (A10)
Z36	EXIT BLOCKED, OBSTRUCTED	T 31.10.070 (A 4)
Z37	EXIT CORRIDOR OR AISLE OBSTRUCTED OR WIDTH REDUCED	T 31.10.070 (A 5)

STANDARD VIOLATION CODES

Violation Ref.	Violation / Description	Fire Code Reference
	B = Building Code; P = FMO Policies; M = Mechanical Code; N = NFPA; E = Electrical Code; T = City Code; U = Uniform Fire Code	
Z38	EXIT SIGN MISSING OR NOT WORKING	T 31.10.070 (A 6)
Z39	FIRE EXT. MISSING, DISCHARGED OR WRONG TYPE	T 31.10.070 (A 7)
Z40	FIRE ALARM DEVICE/FIRE EXT. SYS BLOCKED/OBSTRUCTED	T 31.10.070 (A 9)
Z41	FIREFIGHTING APPLIANCE BLOCKED OR UNUSABLE	T 31.10.070 (A 8)
Z42	POSSESSION OR USE OF ILLEGAL FIREWORKS	T 31.10.070 (A16)
Z42.1	USE OF ILLEGAL FIREWORKS - IMMINENT HAZARD	T 31.10.070 (A23)
Z43	ILLEGAL STORAGE OF FIREWORKS	T 31.10.070 (A17)
Z43.1	ILLEGAL SALE OF LEGAL FIREWORKS	T 31.10.070 (A18)
Z43.2	SALE OF ILLEGAL FIREWORKS	T 31.10.070 (A18)
Z44	ILLEGAL COMMERCIAL FIREWORKS DISPLAY	T 31.10.070 (A19)
Z45	WORK W/O A REQUIRED CERT. OF FITNESS	T 31.10.070 (A11)
Z46	EMPLOYEE WORKING W/O A REQUIRED CERT. OF FITNESS	T 31.10.070 (A12)
Z47	MOBILE FUELING OPERATION IN VIOLATION OF FIRE CODE	T 31.10.070 (A15)
Z48	BURNING IN VIOLATION OF FIRE CODE	T31.10.070 (A21); 307.1-307.5
Z49	PARKING ON A POSTED FIRE ACCESS ROAD	T 31.10.070 (A13)
Z50	ILLEGAL OCC IN VIOL OF IBC OR TITLE 28	T 31.10.070 (A20)
Z51	REP. FALSE ALARMS IN OCC WITH DETECTION SYSTEM	T 31.10.070 (A22)
Z52	IMMINENT HAZARD TO LIFE AND PROPERTY	T 31.10.070 (A23)
Z53	FAILURE TO INSTALL REQUIRED FIRE SPRINKLER SYSTEM	T 31.10.070 (A24)