



PUBLIC HEALTH DIVISION
Drinking Water Services

Kate Brown, Governor

Oregon
Health
Authority

800 NE Oregon Street, #640
Portland, OR 97232-2162
Phone: 971-673-0191
Fax: 971-673-0694
www.healthoregon.org/DWP

March 15, 2018

Yone Akagi, PE
Water Quality Manager
Portland Water Bureau
1900 N. Interstate Ave.
Portland, OR 97227

Re: Corrosion Control Treatment Pilot Study Plan – Revision 1

Dear Yone:

Thank you for your February 23, 2018 submittal to the Oregon Health Authority's Drinking Water Services (DWS) of your revision to the Portland Water Bureau's Corrosion Control Treatment Pilot Study Plan. Portland Water Bureau is proposing to limit the pilot testing phase and to use the bench-scale testing results along with some limited data from early pilot testing to select an interim OCCT strategy. The pilot testing will continue as part of the filtration project to help determine the long-term OCCT approach.

The proposed revision meets the requirements set forth in section 4.2.1 of the "OCCT Evaluation Technical Recommendations for Primacy Agencies and Public Water Systems" document. DWS accepts this revision and looks forward to receiving a report with the results by July 31, 2018.

If you have any questions, please feel free to call me at (971) 673-0191.

Sincerely,

Carrie Gentry, PE
Regional Engineer
Drinking Water Services