
## Notes:

- 1. Install concrete pad at all locations. Comply with all ADA requirements if installed in a sidewalk
- 2. All fill material shall be compacted and tested according to the City of Portland Standard Construction Specifications.
- 3. Sampling station door to face 90° from street such that hydrant nozzle is directed toward the nearest oncoming traffic.
- 4. Paint aluminum base contact surface with tar mastic prior to installing concrete.

The selection and use of this Standard Drawing, while designed in accordance with generally accepted engineering principles and practices, is the sole responsibility of the user.



Standard Drawing Title

**SAMPLING STATION** 

Note:
All material and workmanship shall
be in accordance with City of Portland
Standard Construction Specifications.

Jul 15 2010 **Effective Date** PWB 1 Calc. Book No.

Baseline Report Date Jul 15 2010

P-825

Standard Drawing No.