



Mingus Mapps, Commissioner  
Gabriel Solmer, Director



1120 SW Fifth Avenue, Room 405  
Portland, Oregon 97204-1926  
Information: 503-823-7404  
Portland.gov/water

**DATE:** May 13, 2022

WQ 0.10.14.4

**TO:** Oregon Health Authority, Drinking Water Services

**SUBJECT:** Monthly Report for April 2022  
Bilateral Compliance Agreement  
Intake *Cryptosporidium* Results  
PWS # 4100657

To Whom It May Concern:

Enclosed are results of laboratory analyses for *Cryptosporidium* from the Bull Run raw water intake for April. Monitoring for *Cryptosporidium* at the Bull Run intake is done to comply with the interim measures of the Bilateral Compliance Agreement (Oregon Health Authority, December 18, 2017).

Analyses for *Cryptosporidium* and *Giardia* were performed by the PWB Laboratory (see attached report). Also attached are copies of the monthly turbidity and raw coliform reports previously submitted to OHA in compliance with the SWTR. Results for the reporting month are summarized below:

***Cryptosporidium*, *Giardia*, Turbidity and Fecal Coliforms Data Summary for the Reporting Month**

<i>Cryptosporidium</i> and <i>Giardia</i> Field Samples				<i>Cryptosporidium</i> Recoveries		Fecal Coliforms	Turbidity
No. of Samples	Total Volume (L)	Total No. <i>Cryptosporidium</i> Oocysts	Total No. <i>Giardia</i> Cysts	No. of Matrix Spikes	Average Matrix Spike Recovery (%)	Highest Count (CFU/100 mL)	Highest Reading (NTU)
10	500	0	0	1	70.7	1	0.59

If you have any questions regarding these results, please contact me at 503-823-6135.

Sincerely,

Ann Levy  
Environmental Manager

**Transmitted:** Four pages (including this transmittal memo) emailed to [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us) on this date.



**Portland Water Bureau Laboratory**  
2010 N Interstate Ave, Portland, OR 97227

***Cryptosporidium and Giardia* Laboratory Analysis Report**

<u>Water System Information</u>				<u>Sample Information</u>			
<b>PWS ID:</b>	OR4100657			<b>Collection Month &amp; Year:</b>	April 2022		
<b>PWS Name:</b>	Portland Water Bureau 1900 N Interstate Avenue Portland, Oregon 97227			<b>Report Date:</b>	May 5, 2022		
<b>County:</b>	Multnomah			<b>Monitoring Regime:</b>	Bilateral Compliance Agreement		
				<b>Source Water:</b>	Bull Run Intake - WTP-A		

PWB Sample ID	Loc ID	Sample Collection Date	Sample Type	Sample Volume Filtered (L)	Analysis Method	<i>Cryptosporidium</i>			<i>Giardia</i>		
						No. of Oocysts Spiked	No. of Oocysts Counted	Oocyst Matrix Spike Recovery (%)	No. of Cysts Spiked	No. of Cysts Counted	Cyst Matrix Spike Recovery (%)
BC74837	Intake 2PIS	4/3/2022	Field	50	1623.1	0	0		0	0	
BC74838	Intake 2PIS	4/4/2022	Field	50	1623.1	0	0		0	0	
BC74839	Intake 2PIS	4/4/2022	MS	51	1623.1	99	70	70.7	100	81	81
BC74840	Intake 2PIS	4/5/2022	Field	50	1623.1	0	0		0	0	
BC74841	Intake 2PIS	4/6/2022	Field	50	1623.1	0	0		0	0	
BC75681	Intake 2PIS	4/10/2022	Field	50	1623.1	0	0		0	0	
BC75682	Intake 2PIS	4/12/2022	Field	50	1623.1	0	0		0	0	
BC76315	Intake 2PIS	4/17/2022	Field	50	1623.1	0	0		0	0	
BC76316	Intake 2PIS	4/19/2022	Field	50	1623.1	0	0		0	0	
BC77100	Intake 2PIS	4/24/2022	Field	50	1623.1	0	0		0	0	
BC77101	Intake 2PIS	4/26/2022	Field	50	1623.1	0	0		0	0	

Unless otherwise noted, all data were generated in accordance with EPA Method 1623/1623.1 and 100% of the filtered volume was examined for each sample.

Reviewed by Marsha Farooqui

Date Reviewed: 05/09/2022

# OHA - Drinking Water Services - Turbidity Monitoring Report Form

**County: Multnomah**

Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

**Portland Water Bureau**

**ID #: OR 4100657**

**WTP-A**

**Month/Year: 04/2022**

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading (NTU)
1	0.34	0.35	0.34	0.38	0.35	0.33	<b>0.38</b>
2	0.29	0.28	0.29	0.30	0.27	0.28	<b>0.30</b>
3	0.30	0.30	0.30	0.30	0.27	0.27	<b>0.30</b>
4	0.28	0.28	0.42	0.39	0.34	0.32	<b>0.42</b>
5	0.32	0.33	0.34	0.34	0.32	0.30	<b>0.34</b>
6	0.30	0.32	0.34	0.34	0.35	0.34	<b>0.35</b>
7	0.34	0.34	0.33	0.33	0.33	0.32	<b>0.34</b>
8	0.32	0.33	0.33	0.32	0.31	0.30	<b>0.33</b>
9	0.30	0.30	0.34	0.33	0.34	0.30	<b>0.34</b>
10	0.34	0.29	0.30	0.30	0.28	0.28	<b>0.34</b>
11	0.29	0.29	0.53	0.44	0.41	0.45	<b>0.53</b>
12	0.45	0.34	0.38	0.33	0.59	0.45	<b>0.59</b>
13	0.40	0.35	0.39	0.36	0.45	0.35	<b>0.45</b>
14	0.35	0.33	0.33	0.33	0.31	0.32	<b>0.35</b>
15	0.33	0.30	0.29	0.32	0.33	0.31	<b>0.33</b>
16	0.29	0.30	0.30	0.28	0.29	0.29	<b>0.30</b>
17	0.28	0.29	0.30	0.30	0.30	0.31	<b>0.31</b>
18	0.30	0.32	0.32	0.31	0.31	0.29	<b>0.32</b>
19	0.29	0.28	0.28	0.30	0.30	0.30	<b>0.30</b>
20	0.30	0.32	0.32	0.33	0.34	0.33	<b>0.34</b>
21	0.35	0.41	0.44	0.32	0.30	0.30	<b>0.44</b>
22	0.32	0.37	0.34	0.32	0.30	0.30	<b>0.37</b>
23	0.30	0.33	0.32	0.32	0.32	0.39	<b>0.39</b>
24	0.36	0.37	0.35	0.36	0.31	0.32	<b>0.37</b>
25	0.34	0.34	0.37	0.33	0.34	0.35	<b>0.37</b>
26	0.32	0.32	0.33	0.30	0.35	0.30	<b>0.35</b>
27	0.33	0.35	0.33	0.31	0.37	0.48	<b>0.48</b>
28	0.51	0.34	0.42	0.36	0.33	0.34	<b>0.51</b>
29	0.35	0.33	0.33	0.30	0.34	0.33	<b>0.35</b>
30	0.34	0.32	0.31	0.32	0.33	0.30	<b>0.34</b>

Slow Sand/Membrane/DE Filtration/Unfiltered			Monthly summary	
95% of daily turbidity readings ≤ 1 NTU? <sup>1</sup>	<b>N/A</b>	CT's met everyday?	Chlorine residual at entry point always ≥ 0.2 mg/L?	Chlorine residual measured in 95% of distribution samples?
All daily turbidity readings ≤ 5 NTU?	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>

<sup>1</sup>Filtered systems only

Signature: Anna Vosa  
Anna Vosa, P.E.

Date: 5/7/22

## OHA Drinking Water Services - Raw Coliform Data (Unfiltered)

Portland Water Bureau

ID#: OR 4100657

Month/Year: 04/2022

Date	Fecal Coliform (CFU/100mL)	Comments
4/1/2022	<1	
4/2/2022	<1	
4/3/2022	<1	
4/4/2022	<1	
4/5/2022	<1	
4/6/2022	1	
4/7/2022	<1	
4/8/2022	<1	
4/9/2022	<1	
4/10/2022	<1	
4/11/2022	<1	
4/12/2022	<1	
4/13/2022	<1	
4/14/2022	<1	
4/15/2022	<1	
4/16/2022	<1	
4/17/2022	<1	
4/18/2022	<1	
4/19/2022	<1	
4/20/2022	<1	
4/21/2022	<1	
4/22/2022	<1	
4/23/2022	<1	
4/24/2022	<1	
4/25/2022	<1	
4/26/2022	1	
4/27/2022	<1	
4/28/2022	<1	
4/29/2022	<1	
4/30/2022	<1	

Note: Fecal Coliform sampled at active Headworks Raw Water Intake (either 2P or 2PIS)

**Six Month Summary:**

# of Samples For Fecal Coliform:	177
# of Samples > 20 CFU/100mL:	0
Percent:	0.0%