



PLACE COVER FLUSH WITH FINISH GRADE.

- IN STREET, SIDEWALK, OR PAVED AREA - USE STD. DETAIL P-259
- IN LANDSCAPE AREA - USE STD. DETAIL P-261

**NOTES:**

1. USE 6" DIA. CLEANOUT FOR 6" OR LARGER DIA. LATERAL PIPE UNLESS OTHERWISE NOTED.
2. CLEANOUTS SHALL NOT BE LOCATED IN BIKE PATHS OR IN CURBSIDE BUS OR TRUCK LOADING ZONES.
3. POUR COMMERCIAL GRADE CONCRETE COLLAR AGAINST CURB WHEN DISTANCE BETWEEN CURB AND COLLAR IS LESS THAN 6 INCHES.
4. INSTALL VAC-A-TEE® (OR APPROVED EQUAL) ACCORDING TO THE MANUFACTURER'S RECOMMENDATIONS.
5. IN RUNNING SOILS, INSTALL CASING DURING VACUUM EXCAVATION OF HOLE.

**SIDE VIEW**

The selection and use of this Standard Detail, while designed in accordance with generally accepted engineering principles and practices, is the sole responsibility of the user.



Bureau of Environmental Services  
CITY OF PORTLAND, OREGON

*Walter Dyer*  
Chief Engineer

Standard Detail Title

**Sanitary Sewer  
Cleanout Over Existing Lateral**

Note:  
All material and workmanship shall be in accordance with the City of Portland Standard Construction Specifications.

Effective Date: 03-24-14

Calc. Book No.: N/A

Baseline Report Date: N/A

Standard Detail No.

**P-263**