


SECTION A-A



PLAN

NOTES:

- CONCRETE SHALL BE STRUCTURAL CONCRETE HAVING A MINIMUM 28-DAY COMPRESSIVE STRENGTH OF 4,000 PSI.
- REINFORCEMENT SHALL HAVE A MINIMUM YIELD STRENGTH OF 60,000 PSI (GRADE 60).
- LAP SPLICES SHALL BE A MINIMUM OF 24 BAR DIAMETERS IN LENGTH UNLESS OTHERWISE NOTED.
- ALL REINFORCING HOOPS AND BARS SHALL HAVE A MINIMUM 1½" CLEARANCE TO OUTSIDE SURFACES, INCLUDING TO THE INSIDE FACE AT OPENING.

The selection and use of this Standard Drawing, while designed in accordance with generally accepted engineering principles and practices, is the sole responsibility of the user.

Manufacturing Standards for Precast Concrete Products

Appendix A

Top Slab "A" for Precast Maintenance Hole



Bureau of Environmental Services
CITY OF PORTLAND, OREGON

William Ryan

Chief Engineer

Digitally signed by William Ryan
Date: 2020.08.27 08:55:09
-0700

Calc. Book No.
001

Effective Date
01-01-09

Standard Drawing No.

P-140